

P.C.No 11

Email/Fax
PC no.11..

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn1.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1711 Jaipur, Dated: 18/8/2020

The Superintending Engineer (JCC),
Jaipur Discom,
Jaipur.


Sub:- Administrative approval for laying of 33 kV XLPE cable from 33 kV Amber feeder to 33/11 KV S/S power transformer at Laxman doongri, Distt.-Jaipur(JCC).

विषय:- 33 के.वी. आमेर फीडर से 33/11 केवी सब-स्टेशन लक्ष्मण डूंगरी में स्थित पावर ट्रांसफार्मेर तक 33 केवी अंडरग्राउंड केबल डालने के कार्य की प्रशानिक स्वीकृति हेतु (जयपुर शहर वृत्त)।

Ref: - TA to ZCE(O&M-JZ), Jaipur office letter no. 4313 dated 13.02.2020.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- i) Laying of 120 mtrs 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from Amber feeder (from existing 4-pole structure) to new power transformer on 33/11 KV S/S Laxman doongri.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)