

Email/Fax

PC no. 14

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE(Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 177 Jaipur, Dated: 13-8-2020

The Superintending Engineer (O&M),  
Jaipur Discom,  
Dholpur.

Sub:- Ex-post facto administrative approval for erection of 33 KV line from 220 KV GSS Dholpur to 33/11 KV S/S Basai Dang, Distt.-Dholpur.


विषय:- 220 के.वी. ग्रिड सब-स्टेशन धौलपुर से 33/11 के.वी. सब-स्टेशन बसई डांग, जिला- धौलपुर तक 33 के.वी. लाइन के निर्माण की कार्योपरान्त प्रशासनिक स्वीकृति हेतु ।

Ref: - Your office letter no. 1909 dated 13.07.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- i) Erection of 25.2 km 33 KV S/C O/H line on ACSR Dog conductor plus 2.65 Km 33 Kv S/C 3x300 sqmm.U/G XLPE cable from 220 KV GSS Dholpur to 33/11 KV S/S Basai Dang.

Note:- The previous administrative approval issued vide this office letter no. 280 (PC No. 11) dt. 08.06.17 for erection of 21.0 Km 33 KV S/C O/H line plus 3.0 Km S/C U/G cable is hereby withdrawn.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)