

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 1200 Jaipur, Dated: 7/2/2020

The Superintending Engineer (O&M),
Jaipur Discom,
Bharatpur.

Sub:- **Administrative approval for creation of 33/11 KV S/S at Jotarhulla, P.S.-Pahadi, Distt. Bharatpur.**

विषय- 33/11 के.वी. सब-स्टेशन जोतारहुल्ला, प.स.-पहाड़ी, जिला- भरतपुर के निर्माण की प्रशासनिक स्वीकृति हेतु।


Ref: - Your office letter no. 8222 dated 16.01.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Creation of 1x5.0 MVA, 33/11 KV S/S at Jotarhulla, P.S. Pahadi, Distt. Bharatpur with 03 nos. 11 KV outgoing feeders.
- (ii) Erection of 9.0 Km. 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 KV Gopalgarh(Udaipur Niham) feeder emanating from 132 KV GSS Pahadi to proposed S/S at Jotarhulla at a distance of 11.0 KM from 132 KV GSS Sikri.


Note:-

1. It is directed to ensure that work of shifting the load of 33/11 KV S/S Udaipur Niham & Dayna Ka Bass from existing 33 KV Udaipur Niham feeder emanating from 132 KV GSS Pahadi to 132 KV Sikri.
2. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)