

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 1204 Jaipur, Dated: 7/2/2020

The Superintending Engineer (JPDC),
 Jaipur Discom,
 Jaipur.

Sub:- Administrative approval for bifurcation of 33 KV Dudu feeder from 132 KV GSS Dudu, Distt.-Jaipur (JPDC).

विषय:- 33 के.वी. दूद फीडर (जो 132 के.वी. ग्रिड सब-स्टेशन दूद से निकल रहा है) के विभाजन कार्य की प्रशासनिक स्वीकृति हेतु, जिला- जयपुर (जयपुर जिला वृत्त)।

Ref: - 1) Your office letter no.8341 dated 03.01.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Erection of 6.2 KM O/H line on ACSR Dog conductor from 132 KV GSS Dudu to existing 33 KV Dudu feeder T-off at a distance of 9.2 Km from 33/11 KV S/S Mozmadabad.
- (ii) Erection of 4.25 KM O/H line on ACSR Dog conductor plus 110 mtrs 33 KV D/C 3x300 Sq.mm. XLPE U/G cable (for NH-8 crossing) from 132 KV GSS Dudu to existing 33 KV Dudu feeder T-off at a distance of 4.6 Km from 33/11 KV S/S Dudu.

Note:-

1. The point no. 3 of previous administrative approval issued vide this office letter no. 3186 (PC-138) dated 07.01.2011 is hereby withdrawn.
2. After the proposed bifurcation work, proposed 33 KV Mozmadabad feeder emanating from 132 KV GSS Dudu will cater the load of 33/11 KV S/S Mozmadabad, Akhepura & Lohrdi and proposed 33 KV Naraina feeder emanating from 132 KV GSS Dudu will cater the load of 33/11 KV S/S Sawarda & Naraina and remaining 33 KV Dudu feeder emanating from 132 KV GSS Dudu will supply only 33/11 KV S/S Dudu.
3. The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.

(M.L. Gupta)
 7.2.2020

**Superintending Engineer
 (Plan & Montg.)**

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

(M.L. Gupta)
 7.2.2020
**Superintending Engineer
 (Plan & Montg.)**