

P.C.No.54

Email/Fax  
PC no.54.

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1282 Jaipur, Dated: 3/3/2020

The Superintending Engineer (JCC),  
Jaipur Discom,  
Jaipur.

**Sub:- Administrative approval for laying 33 KV U/G cable as a second source of supply for feeding 33/11 KV S/S Krishi Upaj Mandi, Distt. Jaipur (JCC).**


विषय:- 33/11 के. वी. सब- स्टेशन कृषि उपज मंडी, जिला- जयपुर (जयपुर शहर वृत्त) को 33 के.वी. अंडरग्राउंड केबल खींचकर विद्युत आपूर्ति का द्वितीय स्रोत प्रदान करने के कार्य की प्रशासनिक स्वीकृति हेतु ।

Ref: - TA to ZCE(O&M-JZ), Jaipur office letter no. 3910 dated 24.01.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 1.1 Km 33 KV S/C 3x300 Sq.mm. XLPE U/G cable plus 150 mtrs. 33 KV D/C 3x300 Sq.mm. XLPE U/G cable (for highway crossing) T-off from existing spare 33 KV Chonp feeder from 220 KV GSS VKIA at a distance of 1.4 Km from 132 KV GSS VKIA to 33/11 KV S/S Krishi Upaj Mandi.


Note:- The above works are subject to budget availability as per JPD/rules-1235 letter no. 4181 dated 29.01.2019.

  
3.3.2020  
(M.L. Gupta)

Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
3.3.2020  
Superintending Engineer  
(Plan & Montg.)