

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1308 Jaipur, Dated: 12/03/2020

The Superintending Engineer (JCC),  
Jaipur Discom,  
Jaipur.

**Sub:- Administrative approval for 33 KV interconnections of 33 KV Sirsi feeder & 33 KV Maharana Pratap Nagar feeder at 33/11 KV S/S Sirsi Yard, Distt. Jaipur (JCC).**


विषय:- 33/11 के.वी. सब-स्टेशन सिरसी के यार्ड में, 33 के.वी. सिरसी फीडर एवं 33 के.वी. महाराणा प्रताप नगर फीडर, जिला- जयपुर (जयपुर शहर वृत्त), के 33 के.वी. इंटरकनेक्शन करने के कार्य की प्रशानिक स्वीकृति हेतु ।

Ref: - Your office letter no. 4443 dated 18.02.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- i) Laying of 70 mtr 33 KV 3x300 Sq.mm. XLPE D/C U/G cable (LILO) from 33 KV Maharana Pratap Nagar feeder to control room of 33/11 KV S/S Sirsi.
- ii) Laying of 70 mtr 33 KV 3x300 Sq.mm. XLPE D/C U/G cable from control room of 33/11 KV S/S Sirsi to existing 33 KV Bus at the yard of 33/11 KV S/S Sirsi.


Note:- The above works are subject to budget availability as per letter no. JPD/rules-1235 D. 4181 dated 29.01.2019.

  
12.3.2020

(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
12.3.2020

Superintending Engineer  
(Plan & Montg.)