

P.C. 59

Email/Fax
PC no. 59

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1323 Jaipur, Dated: 19/3/2020

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for 33 KV interconnection of 33 KV Saipura feeder and 33 KV Water works feeder emanating from 132 KV GSS J.Ramgarh, Distt.-Jaipur (JPDC) (As alternate supply).


विषय:- 132 के.वी. गिड सब-स्टेशन ज.रामगढ़ से निकलने वाले 33 के.वी. साएपुरा फीडर एवं 33 के.वी. वॉटर वर्क्स फीडर, जिला- जयपुर (जयपुर जिला वृत्त), के 33 के.वी. इंटरकनेक्शन करने के कार्य की प्रशासनिक स्वीकृति हेतु (वैकल्पिक स्रोत के लिये)।

Ref: - TA to ZCE(O&M-JZ), Jaipur office letter no. 4312 dated 13.02.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 170 mtrs.33 KV S/C O/H line on ACSR Dog conductor T-off from existing unutilized 33 KV Water Works feeder (emanating from 132 KV GSS J.Ramgarh) at a distance of 1.1 Km from 33/11 KV S/S Saipura.

Note:- The above works are subject to budget availability as per letter no. JPD/rules-1235 D. 4181 dated 29.01.2019.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


19.3.2020
Superintending Engineer
(Plan & Montg.)