

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1957 Jaipur, Dated: 28-10-2020.

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for 33 KV interconnections from 132 KV GSS Bahadurpur, Distt. Alwar.


विषय:- 132 के.वी. ग्रिड सब- स्टेशन बहादुरपुर, जिला- अलवर, से 33 के.वी. इंटरकनेक्शन करने के कार्य की प्रशासनिक स्वीकृति हेतु ।

Ref: - XEN(O&M), K.G. Bas office letter no. 2440 dated 22.10.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 8.2 Km 33 KV S/C O/H line on ACSR Dog conductor from 132 KV GSS Bahadurpur to 33/11 KV S/S Khudina. (for catering the load of 33/11 KV S/S Khudina & Kithoor)
- (ii) Erection of 5.3 Km 33 KV D/C O/H line on ACSR Dog conductor from 132 KV GSS Bahadurpur to 33/11 KV S/S Bahadurpur.(for catering the load on 33/11 KV S/S Bahadurpur on one feeder and 33/11 KV S/S Chikani on another feeder)
- (iii) Erection of 15.0 KM 33 KV S/C O/H line on ACSR Dog conductor from 132 KV GSS Bahadurpur to 33/11 KV S/S Chirkhana.

Note:- The above works are included in APP 2020-21.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)