

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1751 Jaipur, Dated: 2/9/2020

The Superintending Engineer (O&M),
Jaipur Discom,
Baran.

Sub:- Revised administrative approval for 33 KV interconnection from 132 KV GSS Kishanganj to 33/11 KV S/S Relawan, Distt.-Baran.

विषय:- 132 के.वी जी.एस.एस किशनगंज से 33/11 के.वी सब-स्टेशन रेलवान तक 33 के.वी. इंटरकनेक्शन करने के कार्य की संशोधित प्रशासनिक स्वीकृति हेतु ।

Ref: - (i) ZCE (O&M-KZ), Kota office letter no. 729 dated 06.08.2020.
(ii) This office letter no. 176 (PC no.- 04) dated 16.05.2017.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- i) Erection of 5.9 Km 33 KV S/C O/H line plus 100 mtrs D/C 33 KV 3x300 Sq.mm. XLPE U/G cable for NH27 crossing from 132 KV GSS Kishanganj to existing 33 KV line Kishanganj to Relawan.


Note:- The point no. (ii) of previous administrative approval issued vide this office letter no. 176 (PC no.- 04) dated 16.05.2017 is hereby withdrawn.



(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


2.9.2020
Superintending Engineer
(Plan & Montg.)