

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1906 Jaipur, Dated: 14.10.2020

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for erection of new 33 KV Bhugor feeder from 220 KV GSS Alwar, Dist. Alwar.


विषय:- 220 के. वी. ग्रिड सब-स्टेशन अलवर से नया 33 के.वी. भुगोर फीडर खीचने के निर्माण कार्य की प्रशासनिक स्वीकृति हेतु, जिला- अलवर ।

Ref:- TA to ZCE(O&M-JZ) office letter no. 298 dated 08.06.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- i) Laying of 0.16 KM 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from 220 KV GSS Alwar to already existing standby section of U/G cable for 33 KV Laldiggi feeder emanating from 220 KV GSS Alwar.
- ii) Laying of 2.38 KM 33 KV S/C 3x300 Sq.mm. XLPE U/G cable from existing 33 KV Laldiggi feeder line G.O. to existing 33 KV Bhugor bypass standby cable.

Note:- After the proposed bifurcation work, proposed 33 KV Bhugor feeder emanating from 220 KV GSS Alwar will cater the load of 33/11 KV S/S Bhugor & Stadium and remaining 33 KV Laldiggi feeder emanating from 220 KV GSS Alwar will cater the load of 33/11 KV S/S Bhura Sidh.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)