

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1908 Jaipur, Dated: 14.10.2020

The Superintending Engineer (O&M),
Jaipur Discom,
Kota.


Sub:- Administrative approval for creation of 33/11 KV S/S at Ayani, P.S.-Itawa, Distt. Kota.

विषय:- 33/11 के.वी. सब-स्टेशन अयानी, प.स.- इटावा, जिला- कोटा के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - Your office letter no. 698 dated 17.06.2020.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman, Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Creation of 1x3.15 MVA, 33/11 KV S/S at Ayani, P.S.- Itawa, Distt. Kota with 03 nos. 11 KV outgoing feeders.
- (ii) Erection of 4.5 KM 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 KV Ayana feeder emanating from 132 KV GSS Itawa, at a distance of 7.0 KM from 132 KV GSS Itawa to proposed 33/11 KV S/S Ayani.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)