

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 07

Jaipur, Dated: 01-04-2021

The Superintending Engineer (O&M),
Jaipur Discom,
Kota.

Sub:- Administrative approval for 33 KV interconnection of 33 KV Aanwa feeder emanating from 132 KV GSS Deoli Manjhi to 33 KV Kanwas feeder emanating from 132 KV GSS Sangod, Distt.-Kota.


विषय:- 132 के. वी. जी.एस.एस. देओली माँझी से निकल रहे 33 के.वी आँवा फीडर का 132 के. वी. जी.एस.एस. संगोद से निकल रहे 33 के.वी कनवास फीडर, जिला- कोटा, से 33 के.वी. इंटरकनेक्शन करने के कार्य की प्रशासनिक स्वीकृति हेतु ।

Ref: - ZCE(O&M-KZ), Kota office notesheet no. 2312 dated 07.02.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Erection of 9.5 Km 33 KV S/C O/H line on ACSR Dog conductor from 33/11 KV S/S Aanwa to 33/11 KV S/S Kanwas.


Note:- After the proposed interconnection work, 33 KV Aanwa feeder emanating from 132 KV GSS Deoli Manjhi will cater the load of 33/11 KV S/S Aanwa & Kanwas and 33 KV Kanwas feeder emanating from 132 KV GSS Sangod will cater the load of 33/11 KV S/S Girdharpura.


1.4.21

(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Chief Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


1.4.21

Superintending Engineer
(Plan & Montg.)