

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 09 Jaipur, Dated: 01-4-2021

The Superintending Engineer (O&M),
 Jaipur Discom,
 Bundi.

Sub:- Administrative approval for 33 KV interconnection from 220 KV GSS Silor (Bundi) to 33/11 KV S/S Ramnagar, Distt.- Bundi.


विषय:- 220 के. वी. जी.एस.एस. सिलोर (बूंदी) से 33/11 के. वी. सब- स्टेशन रामनगर, जिला- बूंदी के 33 के. वी. इंटरकनेक्शन करने के कार्य की प्रशासनिक स्वीकृति हेतु ।

Ref: - Your office letter no. 5887 dated 26.02.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 10.0 Km 33 KV S/C O/H line on ACSR Dog conductor plus 150 mtr 33 kV D/C U/G cable for railway crossing from 220 kV GSS Silor (Bundi) to 33/11 KV S/S Ramnagar.

Note:- After execution of above work, new proposed 33 KV Ramnagar feeder from 220 KV GSS Silor will supply 02 nos. of 33/11 KV S/Ss Ramnagar & Gudha Nathawtan and remaining 33 KV Ramnagar feeder from 132 KV GSS Bundi will supply 02 nos. of 33/11 KV S/Ss Tunnel & Hattipura.


 1.4.2021
 (M.L. Gupta)
 Superintending Engineer
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


 1.4.2021
 Superintending Engineer
 (Plan & Montg.)