

P.C.No 6

Email/Fax  
PC no. 06

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 40

Jaipur, Dated: 19/04/2021

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur.

**Sub:- Ex-post facto administrative approval for 33/11 KV S/S RIICO Phulera, Distt.- Jaipur(JPDC).**


विषय:- 33/11 के.वी. सब-स्टेशन रिको फुलेरा, जिला- जयपुर(जयपुर जिला-वृत्त), के निर्माण की कार्योपरान्त प्रशासनिक स्वीकृति हेतु।

Ref: - Your office letter no. 7699 dated 01.03.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Creation of 1x5.0 MVA, 33/11 KV S/S at RIICO Phulera, Distt. - Jaipur (JPDC) with 04 nos. 11 KV outgoing feeder.
- (ii) Laying of 100 mtrs. D/C U/G 3x300 Sq.mm. XLPE Cable from 220 KV GSS Phulera to existing 3.695 KM overhead line plus 750 mtrs. D/C U/G 3x300 sq.mm. XLPE cable from 33/11 KV S/S RIICO Phulera to existing 3.695 KM 33 KV overhead line.

Note:- The previous administrative approval issued vide this office letter no. 2572 (PC No. 40) dt. 17.02.2016 is hereby withdrawn.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
16.4.21  
Superintending Engineer  
(Plan & Montg.)