

Email/Fax

✓ PC no. 15

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 350

Jaipur, Dated: 2/8/2021

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for conversion of 33 KV O/H line into U/G cable at RPA Road(33 KV NKN-I and NKN-II feeders), at high risk point, Distt.-Jaipur(JPDC).


विषय:- आर.पी.ए. रोड के ऊपर से गुजर रही 33 केवी नाहरी का नाका प्रथम एवं द्वितीय फीडर की ऑवर हेड विद्युत लाइन के स्थान पर अण्डर ग्राउण्ड केबल डालने की प्रशासनिक स्वीकृति हेतु, जिला जयपुर (ज. जि.वृ.)।

Ref: - ZCE(O&M-JZ) office letter no. 360 dated 07.06.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD, JVVNL as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Conversion of existing O/H line of 33 KV NKN-I and NKN-II feeders passing over RPA Road crossing by laying of 150 mtr.33 KV D/C U/G 3X300 sqmm cable at RPA Road crossing for 33 KV NKN-I and NKN-II feeders at high risk point & dismantling of existing 33 KV O/H line.

Note:- (i) The sanction is subject to availability of budget at circle level.
(ii) The work is to be executed under R&M of cable work head.


2.8.21
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan & Montg.), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)