

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEn(Plan)/AEn(33KV works)/D. 372

Jaipur, Dated: 6/8/2021

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur.

**Sub:- Administrative approval for conversion of 33 KV O/H line of 33 KV RIICO-IV feeder into U/G cable near NH-8, Bagru at high risk point, JPD, Distt.- Jaipur (JPDC).**


विषय:- एन.एच.-8, बगरू के पास से गुजर रही 33 केवी रीको-IV फीडर की ओवर हैड विद्युत लाइन के स्थान पर अंडर ग्राउंड केबल डालने की प्रशासनिक स्वीकृति हेतु, जिला- जयपुर ( ज.जि.वृ. )।

Ref: - ZCE(O&M-JZ) office letter no. 847 dated 12.07.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD, JVVNL as per item 2(b) of D.O.P, for the following 33 KV works:-


S.No.	Particulars of Work	Cost (Rs. in lacs)
1.	Conversion of existing O/H line passing over RIICO Road crossing near NH8 by laying of 95 mtr. 33 KV D/C U/G 3X300 sqmm XLPE cable & dismantling of existing 60 mtrs 33 KV O/H line.	5.85

Note:-(i) The sanction is subject to availability of budget at circle level.  
(ii) It is to be ensured that no benefit is to be provided to any private consumer.

  
6.8.21  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan & Montg.), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)