

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No. 416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 396 Jaipur, Dated: 11/8/2021

The Superintending Engineer (O&M),
 Jaipur Discom,
 Baran.

Sub:- Revised administrative approval of 33 kV line for 33/11 KV S/S at Patna, Distt. Baran.


विषय:- 33/11 के.वी. सब-स्टेशन पटना, जिला- बारों, के लिये 33 के.वी. लाइन खींचने के कार्य की संशोधित प्रशासनिक स्वीकृति हेतु ।

Ref:- ZCE(O&M-KZ), Kota office letter no. 359 dated 11.06.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman, Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 4.4 KM 33 KV S/C O/H line on ACSR Dog conductor from 33/11 KV S/S Barla (supplied from 33 kV Antana feeder emanating from 132 kV GSS Atru) to 33/11 KV S/S Patna.

Note:- The point no. (ii) of previous administrative approval issued vide this office letter no. 1912 (PC no.-27) dated 14.10.2020 is hereby withdrawn.


 11.08.21
 Superintending Engineer
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The CE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Chief Engineer (K/Z), Jaipur Discom, Kota.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


 Superintending Engineer
 (Plan & Montg.)