

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 2280 Jaipur, Dated: 4/2/2021

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur.

**Sub:- Revised administrative approval for 33 KV interconnection/ bifurcation of overloaded 33 KV Khejroli feeder emanating from 132 KV GSS Govindgarh, Distt.-Jaipur (JPDC).**


विषय:- ओवरलोडेड 33 के.वी खेजरोली फीडर (जो कि 132 के. वी. जी.एस.एस. गोविंदगढ़ से निकल रहा है), जिला- जयपुर (जयपुर जिला वृत्त), के 33 के.वी. इंटरकनेक्शन/ विभाजन करने के कार्य की संशोधित प्रशासनिक स्वीकृति हेतु ।

Ref: - TA to ZCE(O&M-JZ) office letter no. 2259 dated 31.12.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- i) Erection of 2.2 km 33 KV S/C O/H line on ACSR Dog conductor with 06 nos. 36 feet lattice towers from 220 KV GSS Niwana to existing 33 KV line (spare line emanating from 220 KV GSS Chomu) at a distance of 5.75 KM from 33/11 KV S/S Khejroli.

Note:- The previous administrative approval issued vide this office letter no. 622 (PC No. 32) dt. 30.04.2018 is hereby withdrawn.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)