

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 2367 Jaipur, Dated: 19/02/2021

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.


Sub:- Administrative approval for bifurcation of 33 kV Keshwana IA feeder from 132 kV GSS Keshwana, Distt.-Jaipur (JPDC).

विषय:- 132 के.वी केशवाना से निकल रहे 33 के.वी केशवाना आई. ए. फीडर के विभाजन कार्य की प्रशासनिक स्वीकृति हेतु ।

Ref: - SE(JPDC), Jaipur office letter no. 5973 dated 06.01.2021.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P., for the following 33 KV works:-

- i) Laying of 980 mtrs 33 KV 3x300 Sq.mm. XLPE S/C U/G cable from 132 KV GSS Keshwana to already existing 360 mtrs spare 33 kV ATPEL line
- ii) Laying of 80 mtrs 33 KV 3x300 Sq.mm. XLPE S/C U/G cable (for road crossing) from already existing 360 mtrs ATPEL line (near M/S Deewan private Ltd.) to 714 mtrs unutilized 33 KV Behror-II line (near M/S Bhavik private Ltd.)
- iii) Laying of 30 mtrs 33 KV 3x300 Sq.mm. XLPE S/C U/G cable (for road crossing) from already existing spare 33 KV 714 mtrs Behror -II line to point near M/s Ramco Pvt Ltd.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)