

Email/Fax

PC no. 41

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 2167 Jaipur, Dated: 11/1/2021

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for laying of 33 KV D/C U/G cable in place of 33 KV O/H line of 33 KV Umrain feeder which is passing "Nala" at Motinagar, Distt.-Alwar.

विषय:- 33 के.वी. उमरैन फीडर की 33 के.वी. ओवरहेड लाइन (जो कि मोतिनगर में "नाला" से गुजर रही है) के स्थान पर डबल सर्किट 33 के.वी. अंडर ग्राउंड केबल डालने के कार्य की प्रशासनिक स्वीकृति हेतु, जिला - अलवर।

Ref: - ZCE(O&M-JZ), Jaipur office letter no. 2163 dated 17.12.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Conversion of existing 33 KV O/H line of 33 KV Umrain feeder which is passing "Nala" at Motinagar, Distt.-Alwar by laying of 30 mtrs. 33 KV D/C 3x300 Sq.mm. XLPE U/G cable in place of existing 40 mtrs. 33 KV O/H line.

(M.L. Gupta)
1.1.2021
(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

(M.L. Gupta)
1.1.2021
Superintending Engineer
(Plan & Montg.)