

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 2163 Jaipur, Dated: 11/12/2021

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.


Sub:- Administrative approval for laying 33 KV U/G cable on 33 KV K. G. Bass feeder (for alternate source), Distt.- Alwar.

विषय:- 33 के.वी. के. जी. बास फीडर पर 33 के.वी. अंडरग्राउंड केबल (वैकल्पिक स्रोत के लिए) डालने के कार्य की प्रशासनिक स्वीकृति हेतु, जिला- अलवर।

Ref: - ZCE(O&M-JZ), Jaipur office letter no. 2134 dated 14.12.2020.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 110 mtrs 33 KV 3x300 Sq.mm. XLPE U/G cable on 33 KV K.G. Bass feeder emanating from 220 KV GSS K.G. Bass to convert already existing 110 mtrs S/C U/G cable into D/C U/G cable.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)