

Email/Fax

PC no. 44

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 2166 Jaipur, Dated: 11/1/2021

The Superintending Engineer (O&M),  
Jaipur Discom,  
Bharatpur.

**Sub:- Revised administrative approval for interconnection of 33 KV Sainthra feeder, Distt.-Bharatpur.**


विषय:- 33 के.वी. सैंथरा फीडर, जिला- भरतपुर, के इंटरकनेक्शन कार्य की संशोधित प्रशासनिक स्वीकृति हेतु।

Ref: - Your office letter no. 9003 dated 07.12.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 3.0 Km 33 KV S/C O/H line on ACSR Dog conductor plus laying of 0.15 Km 33 KV D/C 3x300 Sq.mm. XLPE U/G cable (in yard of 220 kV GSS Bharatpur) & 0.06 Km 33 KV D/C 3x300 Sq.mm. XLPE U/G cable (For Jaghina road crossing) from 220 KV GSS Bharatpur to 33/11 KV S/S Jaghina.

Note:- The point no. (ii) of previous administrative approval issued vide this office letter no. 513 (PC No. 10) dt. 05.04.2018 is hereby withdrawn.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (B/Z), Jaipur Discom, Bharatpur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)