

Email/Fax  
PC no. 45

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D 2175 Jaipur, Dated: 4/1/2021

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur.


**Sub:-** Administrative approval for shifting of 33 KV O/H line passing over the premises of Sh.Harimohan S/o. Sh. Chhitarmal, Smt. Komal W/o Sh. Harimohan, Village-Genji, P.S.-Dudu, Distt.- Jaipur (JPDC).

विवरण:- श्री हरिमोहन पुत्र श्री छित्तरमल, श्रीमती कोमल पत्नी श्री हरिमोहन, ग्राम-गेंजी, प.स.- दूदू, जिला- जयपुर (जयपुर जिला वृत्त), के परिसर के ऊपर से गुजर रही 33 के.वी. ओवरहैड लाइन को स्थानांतरित करने के कार्य की प्रशासनिक स्वीकृति हेतु।

Ref: - ZCE(O&M-JZ), Jaipur office letter no. 1975 dated 25.11.2020.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(bb) of D.O.P. under deposit work for the following 33 KV works:-

- (i) Shifting of existing 33 KV O/H line passing the premises of Sh. Harimohan S/o Sh. Chhitarmal, Smt. Komal W/o Sh. Harimohan, Village-Genji, P.S.-Dudu, Distt.-Jaipur (JPDC) by laying of 60 mtrs. 33 KV D/C 3x300 Sq.mm. XLPE U/G cable in place of existing 40 mtrs. 33 KV O/H line.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)