

Email/Fax
PC no. 46

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 2225 Jaipur, Dated: 18/1/2021

The Superintending Engineer (O&M),
Jaipur Discom,
Sawai Madhopur.

**Sub:- Revised administrative approval for 33 KV interconnections from 132 KV
GSS Baler, Distt.-Sawai Madhopur.**


विषय:- 132 के.वी जी.एस.एस. बालेर, जिला- सवाईमाधोपुर, से 33 के.वी. इंटरकनेक्शन करने के कार्य
की संशोधित प्रशासनिक स्वीकृति हेतु।

Ref: - Your office notesheet no. 6249 dated 16.12.2020.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 200 mtr 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Baler to 33/11 KV S/S Baler.
- (ii) Erection of 450 mtr 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Baler to 33 KV B. Kalan feeder near 33/11 KV S/S Baler.
- (iii) Erection of 9.5 Km 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Baler to 33/11 KV S/S Kabirpura.

Note:- The previous administrative approval issued vide this office letter no. 1285 (PC No.- 55) dated 05.03.2020 is hereby withdrawn.


18.1.2021
(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The ACE (PPM), Jaipur Discom, Jaipur.
2. The Zonal Chief Engineer (B/Z), Jaipur Discom, Bharatpur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


18.1.2021
Superintending Engineer
(Plan & Montg.)