

✓ Email/Fax  
PC no. 12.

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 307 Jaipur, Dated: 16/7/2021

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur.


**Sub:- Administrative approval for 33 KV interconnection for shifting the load from 33 kV Goner feeder to Nilay kunj feeder, Jaipur, Distt.-Jaipur (JPDC).**

विषय: -33 के.वी. गोनेर फीडर से 33 के.वी. निलयकुंज फीडर पर भार को स्थानांतरित करने के लिए 33 के.वी. इंटरकनेक्शन कार्य की प्रशासनिक स्वीकृति हेतु ।

Ref: - Zonal Chief Engineer (O&M-JZ) office letter no. 567 dated 24.06.2021

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Laying of 70 mtrs 33 KV D/C 3x300 Sq.mm. XLPE U/G cable from 33/11 kV S/S Nilay Kunj to cross the road and connect to the line 33 kV Goner feeder going towards 33/11 kV S/S Shrikishanpura.

  
16.07.21  
Ed Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The CE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Ed Superintending Engineer  
(Plan & Montg.)