

Email/Fax

PC no. 52

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEn(Plan)/AEn(33kV works)/D. 2567 Jaipur, Dated: 30/3/2021

The Superintending Engineer (O&M),
Jaipur Discom,
Baran.

**Sub:-Revised administrative approval of 33 KV line for 33/11 KV S/S
Niwadi, P.S.-Shahbad, Distt. Baran.**


विषय:-33/11 के.वी. सब-स्टेशन निवाड़ी, प.स.-शाहबाद, जिला- बारों, के लिये 33 के.वी.
लाइन खींचने के कार्य की संशोधित प्रशासनिक स्वीकृति हेतु ।

Ref: - ZCE(O&M-KZ) office notesheet no. 2376 dated 24.02.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the revised administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 8.5 Km 33 KV S/C O/H line on ACSR Dog conductor plus laying of 120 mtrs 33 KV 3x300 Sq.mm. XLPE D/C U/G cable (for NH-27 crossing) from 132 KV GSS Mamoni to 33/11 KV S/S Niwadi.

Note:- The point no. (ii) of previous administrative approval issued vide this office letter no. 314 (PC no.-93) dated 28.02.2018 is hereby withdrawn.


(M.L. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (K/Z), Jaipur Discom, Kota.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Superintending Engineer (TW), Jaipur Discom, Jaipur with request to claim the work under DDUGJY scheme.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)