

Email/Fax

PC no.....

54

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 2569 Jaipur, Dated: 30/3/2021

The Superintending Engineer (O&M),  
Jaipur Discom,  
Baran.

**Sub:- Ex-post Facto administrative approval of 33 KV Ardan line emanating from 132 KV GSS Atru, Distt. Baran.**


विषय:- 132 के. वी. ग्रिड सब - स्टेशन अट्रु से निकल रही 33 के.वी. अरदान लाइन,  
जिला:- बारों, के कार्य की कार्योपरान्त प्रशासनिक स्वीकृति हेतु ।

Ref: - Notesheet no. 2309 dated 16.02.2021 by the O/o ZCE(O&M-KZ).

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-


- (i) Erection of 17.2 Km 33 KV S/C O/H line on ACSR Dog conductor with 22 nos. 42 feet lattice tower & 08 nos. 36 feet lattice towers from 132 KV GSS Atru to 33/11 KV S/S Ardan.

Note:- The previous administrative approval issued vide this office letter no. 984 (PC no.-25) dated 20.11.2014 is hereby withdrawn.

  
(M.L. Gupta)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (K/Z), Jaipur Discom, Kota.
2. The ACE (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)