

JAIPUR VIDYUT VITRAN NIGAM LIMITED**OFFICE OF THE SUPERINTENDING ENGINEER****(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.

Telephone & Fax No. 0141-2747206, E-mail:seplan@jvnl.org

No. JPD/SE(Plan & Montg.)/ XEn(Plan)/AEn(33kV works)/D. 672

Jaipur, Dated: 02-11-21

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for shifting of 33 kV O/H line passing over the premises of Govt. upper primary school at village khokhawala, Distt. Jaipur(JPDC).

विषय:- ग्राम खोखावाला में राजकीय उच्च माध्यमिक विद्यालय के परिसर से गुजर रही 33 के.वी ओवरहेड लाइन को हटाने के कार्य की प्रशासनिक स्वीकृति हेतु, जिला -जयपुर (ज.जि.वृ)।

Ref: - ZCE(O&M-JZ) office letter no. 974 dated 19.07.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(bb) of D.O.P under head of R&M work of cable network, for the following 33 KV works:-

S.no.	Particulars of work	Cost(Rs. in Lakhs)
1.	Conversion of existing O/H line passing over Govt. School premises by laying of 275 mtr. 33 kv S/C U/G 3x300 sqmm. XLPE cable & dismantling of existing 180 mtrs 33 kv O/H line.	8.53

Note:-The sanction is subject to availability of budget at circle level in accordance with Chairman Discoms order no. 299 dt. 17.08.2021.

(S.K. Rajput)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

Superintending Engineer
(Plan & Montg.)