

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEn(Plan)/AEn(33KV works)/D.

673

Jaipur, Dated: 02-11-21

The Superintending Engineer (JPDC),
 Jaipur Discom,
 Jaipur.

Sub:- Administrative approval for conversion of various 33 KV O/H line of 33 KV feeders into U/G cable at high risk points under AEn(HTM-DD-II) , Distt. Jaipur(JPDC).

विषय:- विभिन्न हाई रिस्क पॉइंट स्थानों के ऊपर से गुजर रही 33 के वी ओवरहेड लाइन के स्थान पर भूमिगत केबल डालने की प्रशासनिक स्वीकृति हेतु, सहायक अभियंता- (एच टी एम- डीडी-II), जिला- जयपुर (जयपुर जिला वृत्त)।


Ref: - ZCE(O&M-JZ) office letter no 844, 845, 846, 848 dt. 12.07.2021 & 923 dt. 16.07.2021

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD, JVVNL as per item 2(b) of D.O.P, for the following 33 KV works:-

S.No	Particulars of Work	Cost (Rs. in lacs)
i.	Conversion of existing O/H line of 33 KV Nimeda feeder passing over Chaksu Phagi road near Shree ji Vihar by laying of 85 mtr 33 KV D/C U/G 3X300 sqmm XLPE cable with erection of 10 mtr 33 KV S/C O/H line on ACSR Dog conductor & dismantling of existing 45 mtr 33 kV S/C O/H line.	6.05
ii.	Conversion of existing O/H line of 33 KV RIICO-II feeder passing over Balaji Park chauraha on RIICO main road by laying of 80 mtr.33 KV D/C U/G 3X300 sqmm XLPE cable & dismantling of existing 50 mtrs 33 kV O/H line.	5.09
iii.	Conversion of existing O/H line of 33 KV Begus feeder passing over Dehmi Kalan road crossing near Ramnath Banna ji ki Dhani by laying of 65 mtr.33 KV D/C U/G 3X300 sqmm XLPE cable & dismantling of existing 30 mtrs 33 kV O/H line.	3.87
iv.	Conversion of existing O/H line of 33 KV Dhankya feeder passing over Siwar road crossing near Patel nagar by laying of 105 mtr.33 KV D/C U/G 3X300 sqmm XLPE cable & dismantling of existing 70 mtrs 33 kV O/H line.	5.83
v	Conversion of existing O/H line of 33 KV Bad ke Balaji feeder passing over i) Mahapura Road crossing by laying of 85 mtr.33 KV D/C U/G 3X300 sqmm XLPE cable with erection of 70 mtrs 33 KV S/C O/H line on ACSR Dog Conductor and dismantling of existing 100 mtrs 33 kV S/C O/H line.	15.72


ii)Bad ke Balaji Stand near Ajmer road by laying of 140 mtr.33 KV D/C U/G 3X300 sqmm XLPE cable and dismantling of existing 220 mtrs 33 kV S/C O/H line.	
--	--

Note:- The sanction is subject to availability of budget at circle level in accordance with the Chairman Discoms order no.299 dated 17/08/2021.


29.10.21
(S.K Rajput)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan & Montg.), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)