

P.C.No 47

✓ Email/Fax
PC no. 47

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 523

Jaipur, Dated: 11/7/2022

The Superintending Engineer (O&M),
Jaipur Discom,
Dausa.


Sub:- Administrative approval for shifting of 1x5.0 MVA power transformer from 220 kV GSS Mandawar to existing 33/11 kV S/S Mandawar, Distt. Dausa.

विषय:- 220 के.वी. जी.एस.एस. मंडावर से 1x 5.0 एम.वी.ए. पावर ट्रांसफॉर्मर को 33/11 के.वी. सब-स्टेशन मंडावर पर स्थानांतरित करने के कार्य की प्रशासनिक स्वीकृति हेतु, जिला- दौसा।

Ref: - Your office letter no. 724 dated 23.05.2022.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Managing Director as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Shifting of 1x5.0 MVA power transformer from 220 kV GSS Mandawar to 33/11 kV S/S at Mandawar.
- (ii) Laying of 0.25 km D/C, U/G 3x300 Sq.mm. XLPE cable + Erection of 0.3 km 33 KV S/C O/H line on ACSR Dog conductor from 220 KV GSS Mandawar to existing 33/11 kV S/S Mandawar.


(S.K. Rajput)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Additional Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)

01