

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 415 Jaipur, Dated: 10-6-22

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.

Sub:- Administrative approval for creation of 33/11 KV S/S at Chhintroli, Distt. Jaipur(JPDC).

विषय:- 33/11के.वी. सब-स्टेशन छिंतरोली, जिला- जयपुर(ज.जि.वृ) के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - SE(JPDC) Jaipur office notesheet no. 1229 dated 18.05.2022.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-

S.no.	Particulars of work	Estimated Cost (Rs. in Lakhs)
(i)	Creation of 2x5.0 MVA, 33/11 KV S/S at Chhintroli, Dist. Jaipur (JPDC) with 04 nos. 11 KV outgoing feeders.	181.98
(ii)	Erection of 0.32 km 33 kv S/C O/H on ACSR Dog Conductor plus laying of total 0.6 km 33 kv 3x300 Sqmm. XLPE D/C U/G cable (for road crossings) T-off from SSF feeder at a distance of 2.5 km before 33/11 kv S/S HPCL to proposed S/S at Chhintroli.	9.29

Note:- It is directed to install the power transformer in phase wise manner as per the load requirement after due approval of technical sanctioning authority.

(S.K. Rajput) 10.6.2022
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Additional Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

Superintending Engineer
(Plan & Montg.)