

Email/Fax

PC no. 14

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 233

Jaipur, Dt: 6/5/2022

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for creation of 33/11 KV S/S at Nangal Khanjadi, Laxmangarh, Distt. Alwar.


विषय:- 33/11के.वी. सब-स्टेशन नांगल खानजादी, लक्ष्मणगढ़, जिला- अलवर के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - SE(O&M), Alwar office letter no. 15828 dated 08.03.2022.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-


| S.no. | Particulars of work | Estimated Cost (Rs. in Lakhs) |
|-------|--|-------------------------------|
| (i) | Creation of 1X5.0 MVA, 33/11 KV S/S at Nangal Khanjadi, Laxmangarh, with 03 nos. 11 KV outgoing feeders. | 86.93 |
| (ii) | Erection of 0.98 KM 33 KV S/C O/H on ACSR Dog Conductor T-off from 33 KV Jawali feeder from 132 KV GSS Laxmangarh at a distance of 2.3 km from 33/11 kv S/S Jawali to proposed 33/11 KV S/S Nangal Khanjadi. | 8.26 |

Note :- The above works are to be carried out under RDSS Scheme.


(S.K. Rajput) 6.5.2022
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)