

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 231

Jaipur, Dt: 6/5/2022

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.

Sub:- Administrative approval for creation of 33/11 KV S/S at Chopanki-I, Bhiwadi, Distt. Alwar.


विषय:- 33/11के.वी. सब-स्टेशन चोपांकी-I, भिवाड़ी,जिला- अलवर के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - SE(O&M), Alwar office letter no. 646 dated 06.04.2022.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-

S.no.	Particulars of work	Estimated Cost (Rs. in Lakhs)
(i)	Creation of 13 MVA, 33/11 KV S/S at Chopanki-I, Bhiwadi, Distt.-Alwar, with 04 nos. 11 KV outgoing feeders.(new 1x8 MVA & shifting of 1x5 MVA Power transformer from Chopanki)	127.06
(ii)	Laying of 0.45 km D/C, U/G cable and 0.30 km S/C U/G 33 KV 3x300Sq mm XLPE cable with utilizing existing 2.1km33 KV S/C overhead line on ACSR Panther conductor in the route between 132 KV GSS Chopanki to proposed 33/11 KV sub-station Chopanki-I.	31.63

Note :- The above works are to be carried out under RDSS Scheme.


(S.K. Rajput)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)