

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 260

Jaipur, Dt: 6/5/2022

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur

**Sub:- Administrative approval for creation of 33/11 KV S/S at Dudawas, Distt. Jaipur (JPDC).**


विषय:- 33/11केवी सबस्टेशन दूदावास, जिला- जयपुर (जयपुर जिला वृत) के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - SE(JPDC), Jaipur office letter no. 8082 dated 09.03.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-


| S.no. | Particulars of work  | Estimated Cost (Rs. in Lakhs) |
|-------|--|-------------------------------|
| (i)   | Creation of 1x5 MVA, 33/11 KV S/S at Dudawas, P.S.- Kotputli with 04 nos. 11 KV outgoing feeders.  | 98.67                         |
| (ii)  | Erection of 6 km 33 KV S/C O/H line on ACSR Dog conductor from 33/11 kv S/S Bhonawas on 33 kv khelana feeder emanating from 132 kv GSS Paota to proposed 33/11 KV S/S Dudawas. | 88.77                         |

Note :- The above works are to be carried out under RDSS Scheme.

  
(S.K. Rajput)  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)