

Email/Fax

PC no. 3/

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail: seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 250

Jaipur, Dt: 6/5/2022

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur

**Sub:- Administrative approval for creation of 33/11 KV S/S at Sangteda, P.S.-
Kotputli, Distt. Jaipur (JPDC).**


विषय:- 33/11के.वी. सब-स्टेशन संगतेड़ा, पं.स- कोटपुतली, जिला- जयपुर (जयपुर जिला वृत्त) के निर्माण की
प्रशासनिक स्वीकृति हेतु।

Ref: - SE(JPDC), Jaipur office letter no. 6127 dated 15.01.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-


S.no.	Particulars of work	Estimated Cost (Rs. in Lakhs)
(i)	Creation of 1x5 MVA, 33/11 KV S/S at Sangteda, P.S.- Kotputli with 03 nos. 11 KV outgoing feeders.	95.28
(ii)	Erection of 0.95 km 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 kv Paniyala feeder emanating from 220 kv GSS Kotputli at a distance of 14.5 km from 220 KV GSS Kotputli to proposed 33/11 KV S/S Sangteda.	8.71

Note :- The above works are to be carried out under RDSS Scheme.


(S.K. Rajput) 6.5.2022
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)