

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 1177 Jaipur, Dated: 15.03.22

The Superintending Engineer (O&M),  
Jaipur Discom,  
Alwar.

**Sub:- Administrative approval for creation of 33/11 KV S/S at Surer, Rajgarh,  
Distt. Alwar.**


विषय:-33/11 के.वी. सब-स्टेशन सुरेर, राजगढ़, जिला- अलवर के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - ZCE(O&M-JZ) office letter no.3014 dated 26.10.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-


S.no.	Particulars of work	Cost(Rs.in Lakhs)
(i)	Creation of 1x5.0 MVA, 33/11 KV S/S at Surer with 04 nos. 11 KV outgoing feeders.	91.95
(ii)	Erection of 3.0 km 33 kv S/C O/H on ACSR Dog Conductor T-off of Rajpur Bada(Bandikui) feeder at a distance 8 km from 132 KV GSS Rajgarh + laying of 0.2 km S/C, U/G 3X300 sqmm XLPE cable for railway crossing.	42.14

**Note:-** The previous administrative approval of 33/11 KV S/S Surer at S.No.3 issued vide this office letter no. 2172(PC-07) dated 11.05.2010 is hereby withdrawn.

  
15.3.22  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)