

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE(Plan & Montg.)/ XEN(Plan)/AEN(33KV works)/D. 117) Jaipur, Dated: 15.3.22

The Superintending Engineer (O&M),
Jaipur Discom,
Dausa.

Sub:- Administrative approval for creation of 33/11 KV S/S at Khuri Kalan, Distt. Dausa.

विषय:-33/11के.वी. सब-स्टेशन खुरी कलाँ, जिला- दौसा के निर्माण की प्रशासनिक स्वीकृति हेतु।

Ref: - Your office letter no. 3231 dated 05.10.2021.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of Chairman Discoms as per item 2(b) of D.O.P, for the following 33 KV works:-

S.no.	Particulars of work	Cost(Rs.in Lakhs)
(i)	Creation of 1x3.15 MVA, 33/11 KV S/S at Khuri Kalan with 03 nos. 11 KV outgoing feeders.	84.37
(ii)	Erection of 0.13 km 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 kv Padasoli feeder at a distance of 5.2 km from 220 KV GSS Dausa to proposed 33/11 KV S/S	1.81


15-3-22
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.)

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER
(PLAN & MONT.)

Vidyut bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

NO.JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1180 Jaipur, Dt: 15-3.22

The Superintending Engineer (O&M),
Jaipur Discom,
Dausa.

Sub: - Proposal for creation of 1X3.15 MVA,33/11 KV S/S Khuri Kalan,Distt.-
Dausa.


Ref: - Your office letter no. 3231 dated 05.10.2021.

On the above cited subject, it is to intimate that 33 KV I/C's from 132 KV GSS Andhi already approved vide this office letter no.683 (PC-27) dated 21.06.2013 to bifurcate 33 KV Padasoli feeder may be carried out . If any route alteration / cable laying is required, the same may get approved from competent authority. The bifurcation of 33 KV Padasoli feeder may be completed on priority basis to avoid any overloading of 33 KV Padasoli feeder after creation of 33/11 KV S/S Khuri Kalan.


15.3.22
Superintending Engineer
(Plan & Mont.)

Copy forwarded to the following for information & necessary action:-

1. The CE (PPM), Jaipur Discom, Jaipur.
2. The ZCE(O&M-JZ), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Mont.)