

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER**  
**(PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan@jvvn.org

No. JPD/SE (Plan & Montg.)/XEN(Plan)/AEN(33KV works)/D. 1120

Jaipur, Dated: 2/3/2022

The Superintending Engineer (O&M),  
Jaipur Discom,  
Alwar.


**Sub:-** Revised administrative approval for bifurcation of 33 KV Baroda Mev feeder, Distt.-Alwar.

**विषय:-** 33 केवी बडौदा मेव फीडर, जिला अलवर के विभाजन की संशोधित प्रशासनिक स्वीकृति हेतु।  
**Ref:-** SE (O&M), Alwar office letter no. 10006 dated 10.12.2021.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

S.no.	Particulars of work	Cost(Rs. in Lakhs)
1.	Erection of 9.42 KM 33 KV S/C O/H line on ACSR Dog conductor plus 0.08 km 33 KV D/C U/G 3X300 Sqmm. XLPE cable ( for railway crossing) from 132 KV GSS Govindgarh to existing 33/11 KV S/S Baroda Meo.	78.61

Note :- The previous administrative approval issued vide this office letter no. 1084 (PC No.-80) dt. 19.07.2018 is hereby withdrawn.

  
2.3.22  
Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Chief Engineer (PPM), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The SE(TW), Jaipur Discom, Jaipur.
5. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
6. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

  
Superintending Engineer  
(Plan & Montg.)