

Email/Fax

PC no. 27

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 612

Jaipur, Dated: 27/4/18

The Superintending Engineer (JPDC),
Jaipur Discom,
Jaipur.


Sub:- Administrative approval for interconnection of existing overloaded 33 KV Devguda feeder emanating from 132 KV GSS Rampura Dabri under system improvement scheme, Distt.- Jaipur (JPDC).

Ref: - ZCE (O&M-J/Z) office letter no. 153 dated 13.04.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works:-

- (i) Erection of 6.5 KM. 33 KV S/C O/H line + laying of 2.5 KM. 33 KV S/C 3x300 SQmm. XLPE U/G cable from 132 KV GSS Rampura Dabri to 33/11 KV S/S Devguda.

Note: The above works are included in Annual Phase Programme 2018-19, under DDUGJY scheme.




(S.P. Gupta)

Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

 27.04.18

Superintending Engineer
(Plan & Montg.)