

Email/Fax

PC no. 16

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 549 Jaipur, Dated: 11/4/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Alwar.


Sub:- Administrative approval for bifurcation of 33 KV Harsoli feeder emanating from 220 KV GSS K.G. Bas under AEN (O&M), JPD, Kotkasim, Distt. Alwar. (Under DDUGJY Scheme)

Ref: - 1) Your office letter no. 40 dated 02.04.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.


- (i) Erection of existing 5.5 KM 33 KV S/C to D/C line on ACSR Dog Conductor & laying of 0.5 KM 33 KV S/C 3x300 SQmm. XLPE U/G cable, from 132 KV GSS Pur to T-off point of 33 KV Bibirani feeder at a distance of 50 mtr. from 33/11 KV S/S Bibirani.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19


(S.P. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Alwar.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


Superintending Engineer
(Plan & Montg.) 11-4-18