

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
 Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 542

Jaipur, Dated: 10/4/2018

The Superintending Engineer (O&M),
 Jaipur Discom,
 Kota.


Sub:- Administrative approval for creation of 1x3.15 MVA 33/11 KV S/S at Jatwari,
 PS.- Itawa, Distt. Kota. (Under DDUGJY Scheme)

Ref: - 1) Your office letter no. 7852 dated 13.03.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.


- (i) Creation of 1x3.15 MVA, 33/11 KV S/S at Jatwari, PS.- Itawa, Distt. Kota with 3 no. 11 KV outgoing feeder.
- (ii) Erection of 1.5 km. 33 KV S/C O/H line on ACSR Dog conductor T-off from 33 KV Chapol feeder emanating from 132 KV GSS Itawa at a distance of 8.6 km before 33/11 KV S/S Chapol to proposed S/S.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19


 (S.P. Gupta)
 Superintending Engineer
 (Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (K/Z), Jaipur Discom, Kota.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


 Superintending Engineer
 (Plan & Montg.)