



JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF SUPERINTENDING ENGINEER (COMML.)
 Room No.229, Vidyut Bhawan, Jyoti Nagar, Jaipur - 302015
 Tel - 0141-2747041 FAX - 0141 - 2744803
 Email - c_comml@yahoo.com

No. JPD/SE(C)/XEN-C-I/F. / D.813

Dated 23.07.2014

ORDER

As per provision of Clause 2- "Category of Consumer and Character of Service", of TCOS-2004 the character of service is defined as here under :-

- | | | |
|-------|--|----------------------|
| (i) | Contract/actual demand upto 50 KVA | LT Three Phase |
| (ii) | Contract/actual demand above 50 KVA
and upto 1500 KVA | HT 11 KV |
| (iii) | Contract/actual demand above 1500 KVA
and upto 5000 KVA | HT 33 KV |
| (iv) | Contract/actual demand above 5000 KVA | EHV 132 KV or 220 KV |

It has been observed that field officers are accepting the applications for new connection or for extension in load from the existing consumers without following the above norms & thus deviating from the prescribed character of service and processing the case files for sanction by the Competent authority which is violation of provisions of TCOS-2004.

This practice has been viewed seriously by the higher authorities. It is therefore enjoined upon all concerned that in future the case files should only be accepted strictly for the supply voltage as prescribed in the TCOS-2004 and files having deviation in Supply Voltage as mentioned above even as per provision of clause 2 (iv) of TCOS shall be accepted only after taking approval of the Competent Authority authorized for the sanction of the applied load as per D.O.P. Any lapses in this regard may attribute to disciplinary action against defaulters, Strict Compliance of above instructions be adhered.


 (Ashok Mathur)

Superintending Engineer (Comml.)

D/Sunny.new