



EoDB - JPR5-874

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER(Comml.)**

Regd.Office: Vidyut Bhawan, Jyoti Nagar, Jaipur - 302005 Tel - 0141-2747041 FAX - 0141 - 2744803

Website:www.jaipurdiscom.com; Email - [secommml@jvvn.in](mailto:secommml@jvvn.in)

CIN: U40109RJ2000SGC016486

No. JPD/SE(C)/XEn (C-I)/F.1(13)Pt.VII D. 747

Dated: 04/07/2017

**ORDER**

**Sub:Regarding non-requirement of Electrical Inspector Certificate/  
Self certification of installation in case of increase/ decrease of load /  
demand.**

In compliance to the notification No.F.23 (3 )Energy/2015 dated 21.03.2016 issued by Energy Department, GoR and CEA (Measures relating to Safety and Electric Supply) Regulation, 2010, every electrical installation upto 33 KV & 11 KV voltage level shall be inspected, tested and shall be self certified by the owner of the installation with the assistance of Chartered Electrical Safety Engineer before commencement of supply or recommencement after shutdown for six months and above for ensuring observance of safety measures.

In this regard it is clarified that in the event of increase/ decrease in connected load / contract demand where no alteration in the existing 11 KV or 33 KV installation is required, there is no need of obtaining self certification report or the certificate of Electrical Inspector.However, if there is any change in LT installation, the self certification for the same may be obtained from the consumer as per provisions of order JPR5-786.

All concerned are directed to comply with the above instructions.

By order

(A.K. Khandelwal)  
Chief Engineer (HQ)