



JAIPUR VIDYUT VITRAN NIGAM LIMITED

OFFICE OF THE CHIEF ENGINEER (HQ)

Room No.231, Vidyut Bhawan, Jyoti Nagar, Jaipur - 302005

Tel - 0141-2747041 FAX - 0141 - 2744803 Email - c_comml@yahoo.com

CIN:U40109RJ200SGC016486

No.JPD/CE(HQ)/F.

ID.514

Dated: 01-06-2017

ORDER

Sub: Regarding uninterrupted supply to industrial Consumers.

In compliance to Sr.Officers meeting held on dated 30.05.2017 wherein the issue of arranging uninterrupted power supply (No tripping) in the Industrial Area was discussed and accordingly the following instructions are hereby issued:

1. The Field Officer shall ensure that maximum span of industrial feeder be not more than 50 Mtrs. wherever a span more than 50 Mtrs. of the industrial feeder is still existing, same shall be reduced to 50 Mtrs.
2. The field officer shall ensure to provide suitable stay at every 3rd pole O/H line, so as to maintain proper alignment of line and avoiding faults in stormy/rainy season.
3. The field officer will ensure proper Pre-Monsoon and Post-Monsoon maintenance of all industrial feeders alongwith associated 33 KV feeders feeding supply to Industrial Areas.
4. It is also advised to ensure quarterly checking/maintenance of all the 11/33 KV Breakers with proper relay setting by the M&P Wing officers for ensuring smooth and proper operation of Breakers.
5. The sectionaliser shall be provided at adequate locations, preferably four (4) pole structure with Isolators shall be provided at cut points and 'T' points.
6. On lengthy 11KV feeder from which supply is fed in the Industrial Area, an Isolator at every 500 Mtrs. shall be arranged and their proper periodical maintenance shall be ensured for smooth operation.
7. Fault passage Indicators (FPI) shall be provided on each cut point.
8. It is advised that all short of work Viz maintenance, Erection of Poles and Installation of Transformers etc shall be carried out on the day of weekly closure of the Industrial Area. Necessary preparation of such works shall be ensured in advance along with arrangement of required material.
9. Segregation of industrial feeders from rural feeders shall also be taken on priority.
10. Feeders on which mostly industries are existing in rural area, 24 supply be resorted to and augmentation of lines if required may be done on Nigam Cost.

Strict compliance of above instructions be adhered.

By order,

(A.K.Khendelwal)

Chief Engineer(HQ.)