

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE CHIEF ENGINEER (COMMERCIAL)**

JPR5-539

No. JPD/CE(C)/C-I/F.4 (184)/Pt.III/D.582 Dated 13.03.09

**ORDER**

Sub: Installation of 11 KV "Ring Main Unit" (RMU)/11 KV "Ring Main Switch Fuse Unit" for termination of 11 KV underground service line.

On the subject cited above, Orders No. 2036 dt. 11-08-08 (JPR5-490) and No. 2525 dt. 17-10-08 (JPR5-511) were issued for providing "Ring Main Unit" (RMU)/ Ring Main Switch Fuse Unit for termination of 11 KV underground service lines in the premises of prospective H.T. consumers under all categories in Jaipur City by such consumers.

For implementing above directions, difficulties are being faced by the field officers for small consumers upto 500 KVA. The matter was again examined and I am directed to convey the approval of the CMD for following below mentioned procedure in supersession to Orders No. 2036 dt. 11-08-08 (JPR5-490) and No. 2525 dt. 17-10-08 (JPR5-511):-

- a) Consumers having contract/design demand between 50 KVA to 125 KVA be allowed to lay underground cable service line from nearest JVVNL supply point and 11 KV oil switch may be installed in consumer's premise before transformer.
- b) At locations where JVVNL has already installed RMU consumers having contract demand/Designed demand more than 125 KVA may be allowed to install 11 KV RMU with fuses without isolators (both sides extensible) of the same make as installed by JVVNL. In such cases fuses are to be replaced by consumers.
- c) Consumers having demand more than 125 KVA at locations other than (b) be allowed to use 11 KV RMU having fuses where fuses are to be replaced by consumers.

6399 Dtd 23.3.09  
KBN(II)/CEN

(II & CEN)

By order,

*N.M. Sareen* 13.3.2009

(N.M.Sareen)

Chief Engineer (Comm.)

Copy submitted/ forwarded to the following for information and necessary action:-

1. The Director (Finance), JVVNL, Jaipur (with 45 spare copies).
2. The Director (Technical), JVVNL, Jaipur.
3. The Zonal/Dy. Chief Engineer (            Zone/RP), JVVNL, Jaipur/Kota.
4. The Dy. Chief Engineer (MM), JVVNL, Jaipur.
5. The Addl. Supdt. of Police (Vigl.), JVVNL, Jaipur. (with 30 spare copies)
6. The Chief Personnel Officer, JVVNL, Jaipur.
7. The Chief Accounts Officer, JVVNL, Jaipur.
8. The Dy. Chief Engineer / Supdtg. Engineer (Power), RIICO, Jaipur.
9. The Supdtg. Engineer (            ), JVVNL, \_\_\_\_\_.
10. The Secretary, JVVNL, Jaipur.
11. The Sr. AO/AO/AAO (            ), JVVNL, Jaipur.
12. The Executive Engineer (            ), JVVNL, \_\_\_\_\_.
13. The Executive Engineer (            ), JVVNL, \_\_\_\_\_, alongwith 10 spare copies for sending the same upto AENs/JENs/AROs/Accountants level under his jurisdiction.
14. The Executive Engineer (Elect.), J.D.A./R.H.B., Jaipur.
15. Executive Engineer (Griev.), JVVNL, Jaipur.
16. The Company Secretary, JVVNL/RRVNL, Jaipur.
17. The TA/PA to CMD, RVPN / JVVNL, Jaipur
18. PA to MD, Jodhpur/Ajmer Discom, Jodhpur/Ajmer.
19. P.S. to Hon'ble Energy Minister, Rajasthan, Jaipur.
20. P.S. to Secretary (Energy), Govt. of Rajasthan, Jaipur.
21. The Public Relations Officer, JVVNL, Jaipur.
22. The Media Advisor, JVVNL, Jaipur.
23. Sr. Accounts Officer (FP-5), A.G. Audit, Shed No.14/1 Jaipur.
24. Sr. Accounts Officer (CAW-III), A.G. Audit, Shed No.4/1, Jaipur.
25. The Asstt. Engineer (            ), JVVNL, \_\_\_\_\_.
26. The Zonal Commissioner, Ombudsman, Mini Secretariat, Near Collectorate, Jaipur.
27. The Supdtg. Engineer (IT & CRP), Jaipur Discom, Jaipur for putting up the order on the website of Discom.

28.

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

*mm*

Chief Engineer (Comml)