

JPR5-421

JAIPUR VIDYUT VITRAN NIGAM LIMITED
VIDYUT BHAWAN, JYOTI NAGAR, JANPATH, JAIPUR 302005

No. JPD /CE (C)/XEN/C.I/F. 2 (2)/(58)/D. 1907 Dt. 04.10.07

ORDER

Sub: Release of connection to petrol Pumps in rural areas.

Vide order No. JPD/CE (C)/ C.I/F.2 (58)/D.1361 dt. 25-7-07 (JPR5-409) and No. 1695 dt. 6-9-07 (JPR5-413) directions were issued for releasing connection for petrol pumps in rural areas. It was prescribed that the connection be released through single phase line and single phase transformer by recovering the cost of line and transformer from the consumer as deposit work. It was also prescribed that the capacity of single phase transformer to be installed shall be considered, taking into account the applied load for the petrol pump.

The matter has been again considered on the basis of feed back from the field officers and also in accordance with the provisions of "Terms & Conditions for Supply of Electricity- 2004 (TCS-04). It has been decided that single phase connection shall be released through single phase line and single phase transformer upto the load of 5 KW . For the load requirement beyond 5 KW and for getting 24 hours supply, the connection should be released through a dedicated 11 KV feeder from nearest 33/11 KV sub-station. In such case also the entire cost of line and transformer shall be borne by the applicant.

This order is issued in partial modification to the earlier orders, stated herein above, to this extent.

By order,



(B.L. Agarwal)
Chief Engineer (Comml.)

Comp.2/Ch1/order