

JPR5-437

**JAIPUR VIDYUT VITRAN NIGAM LIMITED
VIDYUT BHAWAN, JYOTI NAGAR, JANPATH,
JAIPUR 302005**

No. JPD /CE (C)/XEN/C.I/F. 4 (372)/D.2221

Dt. 14.11.07


ORDER

**Sub: Releasing connection on 11 KV by providing OCB/
Breaker on 11 KV line or 11 KV Horngap Fuse of the
consumer.**

The matter for releasing connection on 11 KV by providing OCB/Breaker on 11 KV line of the consumer came-up for discussion in the meeting of Executive Engineers of Important Industrial areas held on 26-10-07. After discussion it has been decided that now onwards no connection on 11 KV be released without OCB/Breaker on 11 KV line or 11 KV Horngap Fuse of the consumer.

It is enjoined upon all the field officers to strictly adhered to these instructions.

By order,



**(B.L. Agarwal)
Chief Engineer (Comml.)**