

Email/Fax

PC no. 1.9

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail: seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 555 Jaipur, Dated: 13/4/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Bharatpur.

Sub:- Administrative approval for creation of 33/11 KV S/S at Palka in Place of Berru, PS-Nagar, Distt. Bharatpur. (Under DDUGJY Scheme)

Ref: - 1) Your office letter no. 13789 dated 22.03.2018.


In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Creation of 1x3.15 MVA, 33/11 KV S/S at Palka, PS- Nagar, Distt.- Bharatpur with 3 nos. 11 KV outgoing feeder.
- (ii) Erection of 0.4 KM 33 KV S/C O/H line on ACSR Dog Conductor T-off from 33 KV Sikri feeder at a distance of 14.5 KM from 132 KV GSS Nagar to proposed S/S.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19


Note 2: The previously issued sanction vide this office letter no. 10 (PC no. 01) dated 05.04.2016 for creation of 33/11 KV S/S Berru is hereby withdrawn.

Office of SE (IT), JVA, Jaipur
XEN/IT-VV/HAEN(AAO/IT)
PA/JEN/Store/Est/VAO(TW)
R.R. No. 162
Dated 13.4.18
SE (IT)


(S.P. Gupta)
Superintending Engineer
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (B/Z), Jaipur Discom, Bharatpur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.


13.4.18
Superintending Engineer
(Plan & Montg.)