

Email/Fax

PC no. 21

CIN: U40109RJ2000SGC016486

JAIPUR VIDYUT VITRAN NIGAM LIMITED
OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 557

Jaipur, Dated: 13/4/2018

The Superintending Engineer (O&M),
Jaipur Discom,
Karauli.

Sub:- Administrative approval for 3 nos. 33 KV I/C's from 132 KV GSS Mandrayal,
Distt. Karauli. (Under DDUGJY Scheme)

Ref: - 1) Your office letter no.5548 dated 21.03.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- i) Erection of 350 mtrs 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Mandrayal to existing 33 KV line at a distance of 8 KM line from 33/11 KV S/S Rodhai.
- ii) Erection of 330 mtrs 33 KV, S/C O/H line on ACSR Dog Conductor from 132 KV GSS Mandrayal to existing 33 KV line at a distance of 3 KM line from 33/11 KV S/S Mandrayal.
- iii) Erection of 6.0 KM 33 KV S/C O/H line on ACSR Dog Conductor from 132 KV GSS Mandrayal to existing 33 KV line at a distance of 19 KM line from 33/11 KV S/S Langra.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19.

OFFICE OF SE (IT), JAIPUR DISCOM
XEN/IT-W/IT/AEN(A&M/IT)/
PW/JEN/Store/Est/WAO(TW)

R.R. No. 164
Dated 13.4.18

Sh. A. K.

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (B/Z), Jaipur Discom, Bharatpur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

S.P. Gupta

Superintending Engineer
(Plan & Montg.)

S.P. Gupta 13.4.18
Superintending Engineer
(Plan & Montg.)