

Email/Fax

PC no. 11.

CIN: U40109RJ2000SGC016486

**JAIPUR VIDYUT VITRAN NIGAM LIMITED**  
**OFFICE OF THE SUPERINTENDING ENGINEER (PLAN & MONTG.)**

Vidyut Bhawan, Room No.416, Janpath, Jyoti Nagar, Jaipur-302005.  
Telephone & Fax No. 0141-2747206, E-mail:seplan.jvvn@gmail.com

No. JPD/SE (Plan)/AEN(33KV works)/D. 514

Jaipur, Dated: 5/4/18

The Superintending Engineer (JPDC),  
Jaipur Discom,  
Jaipur.

Sub:- Revised Administrative approval for I/C of 33 KV Peepla feeder from 132 KV GSS Bhojpura presently connected from 33 KV Renwal feeder, AEN (O&M), JPD, Phagi.

Ref: - 1) This office Letter No. 770-A (PC No.-6) dated 1.6.12.  
2) Your office letter no.11555 dated 22.03.2018.

In consideration of the proposal furnished vide letter under reference, I am directed to convey the administrative approval of MD as per item 2(b) of D.O.P, for the following 33 KV works.

- (i) Laying of 105 mtr. 33 KV S/C U/G 3x300 Sqmm. XLPE cable in the premises of 132 KV GSS Bhojpura to connect existing 33 KV line sanctioned vide this office letter no. 770-A (PC-6) dated 1.6.12.

Note 1: The above works will be carried out under DDUGJY scheme in APP 2018-19




(S.P. Gupta)

Superintending Engineer  
(Plan & Montg.)

Copy submitted/forwarded to the following for information and necessary action:-

1. The Zonal Chief Engineer (J/Z), Jaipur Discom, Jaipur.
2. The Superintending Engineer (TW), Jaipur Discom, Jaipur.
3. The Superintending Engineer (IT), Jaipur Discom, Jaipur for uploading the sanction order on the website of Jaipur Discom.
4. The Executive Engineer (Montg.), Jaipur Discom, Jaipur.
5. The P.A. to SE (Plan), Jaipur Discom, Jaipur.

 5.4.18

Superintending Engineer  
(Plan & Montg.)